

333 Main Street NW P.O. Box 388 Elk River, MN 55330 Phone: 763-441-7509

Fax: 763-441-9176

DRINKING WATER LABORATORY TEST REPORT

Last Name:

SWAN RIVER MONTESSORI CHARTER

Zip Code: 55362

File #: 95566

First Name:

SCHOOL

Date/Time

in Lab:

1/30/2025 1:18 PM

Address:

500 MAPLE STREET

City:

MONTICELLO

Unique Well #:

State:

MN

Drillers #:

County: Legal:

Ordered By:

DAN FINICAL

Sampled From:

Kitchen Tap

Sampled By:

KIRSTEN HOST

Date/Time Sampled: 01/28/2025 600

Reason For Test: Lead Only

Sample Temp:

22.0 ° C

Received on Ice; No

ANALYTE & METHOD

DATE & TIME OF **ANALYSIS**

MAXIMUM CONTAMINATION TEST RESULTS LEVEL (EPA)

Lead (SM 3113 B-99)

02/03/2025 1510

15.0 µg/L

< 2.5 µg/L

This sample DOES meet EPA guidelines for safe drinking water for the Analytes tested.

Notes:

The test results are only indicative of the sample tested from the sample point on the date collected. This report must not be reproduced, except in full, without the written approval from Water Laboratories, Inc. Minnesota Certification# 027-141-110, Wisconsin Certification #399044470 (for compliance with NR812)

Water Laboratories, Inc.

By: Un

Date: 02/03/2025

Received By CKW L Entered By CKW

Edited By CKW