

# *Swan River Montessori Charter School*

AN AUTHENTIC, PUBLIC MONTESSORI ENVIRONMENT

**Address:** 500 Maple Street, Monticello, MN 55362 • **Phone:** 763-271-SWAN (7926) • **Fax:** 763-295-0075

**Email:** [director@swanrivermontessori.org](mailto:director@swanrivermontessori.org) • **Website:** [swanrivermontessori.org](http://swanrivermontessori.org)

2/5/2025

Swan River Montessori Charter School

500 Maple Street

Monticello, MN 55362

Dear Parents/Guardians, Students and Staff,

On 1/30/2025 SRMCS conducted sampling for lead in drinking water. While the major source of lead exposure for most Minnesota children is paint, lead in plumbing fixtures can add to a person's overall exposure. Drinking water in schools and homes may contain lead from old lead pipes, plumbing fixtures (e.g., fountains and faucets), or solder that joins pipe sections together. A school designee sampled our drinking water and sent it to a certified laboratory for analysis. A summary of these results is included with this letter.

The water sampled had results at or less than 2.5 parts per billion (ppb) for lead in school drinking water. The water at the school does not require action based on our school testing plan.

Our school is committed to protecting student, teacher, and staff health. If you have questions about a lead sample result and actions taken, or if you have concerns, please contact Annette Vemuri at 763-271-7926 or [director@swanrivermontessori.org](mailto:director@swanrivermontessori.org)

To learn more about lead hazards and lead poisoning prevention, MDH Lead Program (<https://www.health.state.mn.us/communities/environment/lead/index.html>).

Sincerely,

SRMCS



333 Main Street NW  
P.O. Box 388  
Elk River, MN 55330  
Phone: 763-441-7509  
Fax: 763-441-9176

---

**DRINKING WATER LABORATORY TEST REPORT**

**Last Name:** SWAN RIVER MONTESSORI CHARTER **File #:** 95566  
**First Name:** SCHOOL **Date/Time in Lab:** 1/30/2025 1:18 PM  
**Address:** 500 MAPLE STREET  
**City:** MONTICELLO **Unique Well #:**  
**State:** MN **Zip Code:** 55362 **Drillers #:**  
**County:**  
**Legal:**

---

**Ordered By:** DAN FINICAL **Sampled From:** Kitchen Tap  
**Sampled By:** KIRSTEN HOST **Date/Time Sampled:** 01/28/2025 600  
**Reason For Test:** Lead Only **Sample Temp:** 22.0 °C  
**Received on Ice:** No

---

<u>ANALYTE &amp; METHOD</u>	<u>DATE &amp; TIME OF ANALYSIS</u>	<u>MAXIMUM CONTAMINATION LEVEL (EPA)</u>	<u>TEST RESULTS</u>
Lead (SM 3113 B-99)	02/03/2025 1510	15.0 µg/L	< 2.5 µg/L

This sample  meet EPA guidelines for safe drinking water for the Analytes tested.

**Notes:**

---

The test results are only indicative of the sample tested from the sample point on the date collected.  
This report must not be reproduced, except in full, without the written approval from Water Laboratories, Inc.  
Minnesota Certification# 027-141-110, Wisconsin Certification #399044470 (for compliance with NR812)

**Water Laboratories, Inc.**

**By:**

**Date:** 02/03/2025

Received By CKW Entered By CKW Edited By CKW