

Swan River Montessori Charter School

AN AUTHENTIC, PUBLIC MONTESSORI ENVIRONMENT

Address: 500 Maple Street, Monticello, MN 55362 • **Phone:** 763-271-SWAN (7926) • **Fax:** 763-295-0075

Email: director@swanrivermontessori.org • **Website:** swanrivermontessori.org

9/14/2026

Swan River Montessori Charter School

500 Maple Street

Monticello, MN 55362

Dear Parents/Guardians, Students and Staff,

On 6/03/2026 SRMCS conducted sampling for lead in drinking water. While the major source of lead exposure for most Minnesota children is paint, lead in plumbing fixtures can add to a person's overall exposure. Drinking water in schools and homes may contain lead from old lead pipes, plumbing fixtures (e.g., fountains and faucets), or solder that joins pipe sections together. A school designee sampled our drinking water and sent it to a certified laboratory for analysis. A summary of these results is included with this letter.

The water sampled had results at or less than 2.5 parts per billion (ppb) for lead in school drinking water. The water at the school does not require action based on our school testing plan.

Our school is committed to protecting students, teachers, and staff health. If you have questions about a lead sample result and actions taken, or if you have concerns, please contact Annette Vemuri at 763-271-7926 or director@swanrivermontessori.org

To learn more about lead hazards and lead poisoning prevention, MDH Lead Program (<https://www.health.state.mn.us/communities/environment/lead/index.html>).

Sincerely,

SRMCS

Final Report

Minnesota Department of Health
Public Health Laboratory
Environmental Laboratory Section
601 Robert St. N., P.O. Box 64899
St. Paul, MN 55164-0899
651-201-5300

PWSID: Swan River Montessori Charter School Program Code: HK Type:
System Name: 4137
City: None

Date Received: 05/19/26 10:14 Collector Name: Facility Staff - Kirsten Host
Rep. Temp. (°C): 18.3 Collector ID: None

MDH Sample Number: 26E2179-01

Location ID: 101 Collect Date: 05/14/26 Field Residual Chlorine Result: None
Sampling Point: 503775 Collect Time: 12:47 Field Fluoride Result: None
Matrix: Drinking Water Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:14	RCC	EPA 200.8	

MDH Sample Number: 26E2179-02

Location ID: 201 Collect Date: 05/14/26 Field Residual Chlorine Result: None
Sampling Point: 503776 Collect Time: 12:50 Field Fluoride Result: None
Matrix: Drinking Water Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.08	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:17	RCC	EPA 200.8	

FINAL REPORT

Report ID: 06032026 85615

Generated: 6/3/2026 8:56:09AM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Swan River Montessori Charter School

MDH Sample Number: 26E2179-03

Location ID: 202
Sampling Point: 503777

Collect Date: 05/14/26
Collect Time: 12:52
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.02	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:18	RCC	EPA 200.8	

MDH Sample Number: 26E2179-04

Location ID: 203
Sampling Point: 503778

Collect Date: 05/14/26
Collect Time: 12:53
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:18	RCC	EPA 200.8	

MDH Sample Number: 26E2179-05

Location ID: 204
Sampling Point: 503779

Collect Date: 05/14/26
Collect Time: 12:55
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:19	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Swan River Montessori Charter School

MDH Sample Number: 26E2179-06

Location ID: 205
Sampling Point: 503780

Collect Date: 05/14/26
Collect Time: 12:56
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:20	RCC	EPA 200.8	

MDH Sample Number: 26E2179-07

Location ID: 206
Sampling Point: 503781

Collect Date: 05/14/26
Collect Time: 12:57
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:21	RCC	EPA 200.8	

MDH Sample Number: 26E2179-08

Location ID: 207
Sampling Point: 503782

Collect Date: 05/14/26
Collect Time: 12:57
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:22	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Swan River Montessori Charter School

MDH Sample Number: 26E2179-09

Location ID: 208
Sampling Point: 503783

Collect Date: 05/14/26
Collect Time: 12:58
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:23	RCC	EPA 200.8	

MDH Sample Number: 26E2179-10

Location ID: 209
Sampling Point: 503784

Collect Date: 05/14/26
Collect Time: 13:00
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:25	RCC	EPA 200.8	

MDH Sample Number: 26E2179-11

Location ID: 210
Sampling Point: 503785

Collect Date: 05/14/26
Collect Time: 13:01
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1436	05/21/26 09:54	05/21/26 14:26	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Swan River Montessori Charter School

MDH Sample Number: 26E2179-12

Location ID: 211
Sampling Point: 503786

Collect Date: 05/14/26
Collect Time: 13:02
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1471	05/22/26 08:12	05/22/26 12:04	DJM2	EPA 200.8	

MDH Sample Number: 26E2179-13

Location ID: 212
Sampling Point: 503788

Collect Date: 05/14/26
Collect Time: 13:02
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1471	05/22/26 08:12	05/22/26 12:05	DJM2	EPA 200.8	

MDH Sample Number: 26E2179-14

Location ID: 213
Sampling Point: 503789

Collect Date: 05/14/26
Collect Time: 13:03
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1471	05/22/26 08:12	05/22/26 12:06	DJM2	EPA 200.8	

FINAL REPORT

Report ID: 06032026 85615

Generated: 6/3/2026 8:56:09AM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Swan River Montessori Charter School

MDH Sample Number: 26E2179-15

Location ID: 301
Sampling Point: 503790

Collect Date: 05/14/26
Collect Time: 13:07
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1471	05/22/26 08:12	05/22/26 12:07	DJM2	EPA 200.8	

MDH Sample Number: 26E2179-16

Location ID: 302
Sampling Point: 503791

Collect Date: 05/14/26
Collect Time: 13:07
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1471	05/22/26 08:12	05/22/26 12:08	DJM2	EPA 200.8	

MDH Sample Number: 26E2179-17

Location ID: 303
Sampling Point: 503792

Collect Date: 05/14/26
Collect Time: 13:09
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6E1471	05/22/26 08:12	05/22/26 12:12	DJM2	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Swan River Montessori Charter School

Results were produced by Minnesota Department of Health, except where noted.

Batch B6E1436 - EPA 200 Series Prep

Blank (B6E1436-BLK1)

Prepared: 05/21/26 09:54 Analyzed: 05/21/26 14:04

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B6E1436-BS1)

Prepared: 05/21/26 09:54 Analyzed: 05/21/26 14:05

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	49.5		ug/L	50		99	85-115			RCC	

Duplicate (B6E1436-DUP1)

Source: 26E2174-04

Prepared: 05/21/26 09:54 Analyzed: 05/21/26 14:07

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.58	1.00	ug/L		<			2	20	RCC	

Duplicate (B6E1436-DUP2)

Source: 26E2179-09

Prepared: 05/21/26 09:54 Analyzed: 05/21/26 14:23

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.28	1.00	ug/L		<			10	20	RCC	

Matrix Spike (B6E1436-MS1)

Source: 26E2174-04

Prepared: 05/21/26 09:54 Analyzed: 05/21/26 14:08

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	52.2		ug/L	50		103	70-130			RCC	

Matrix Spike (B6E1436-MS2)

Source: 26E2179-09

Prepared: 05/21/26 09:54 Analyzed: 05/21/26 14:24

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	46.3		ug/L	50		92	70-130			RCC	

Batch B6E1471 - EPA 200 Series Prep

FINAL REPORT

Report ID: 06032026 85615

Generated: 6/3/2026 8:56:09AM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Swan River Montessori Charter School

Results were produced by Minnesota Department of Health, except where noted.

Batch B6E1471 - EPA 200 Series Prep

Blank (B6E1471-BLK1)

Prepared: 05/22/26 08:12 Analyzed: 05/22/26 11:54

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							DJM2	

LCS (B6E1471-BS1)

Prepared: 05/22/26 08:12 Analyzed: 05/22/26 11:55

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	51.3	1.00	ug/L	50		103	85-115			DJM2	

Duplicate (B6E1471-DUP1)

Source: 26E2041-01

Prepared: 05/22/26 08:12 Analyzed: 05/22/26 11:59

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20	DJM2	

Duplicate (B6E1471-DUP2)

Source: 26E2179-17

Prepared: 05/22/26 08:12 Analyzed: 05/22/26 12:14

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.34	1.00	ug/L		<			5	20	DJM2	

Matrix Spike (B6E1471-MS1)

Source: 26E2041-01

Prepared: 05/22/26 08:12 Analyzed: 05/22/26 11:58

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	42.7	1.00	ug/L	50	<	85	70-130			DJM2	

Matrix Spike (B6E1471-MS2)

Source: 26E2179-17

Prepared: 05/22/26 08:12 Analyzed: 05/22/26 12:13

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	45.8	1.00	ug/L	50	<	91	70-130			DJM2	

FINAL REPORT

Report ID: 06032026 85615

Generated: 6/3/2026 8:56:09AM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Swan River Montessori Charter School

Work Order Comments

Samples were received in proper condition.

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health